

- Previous to entering substation verify grounding, conductors, vandalism and listen for unusual silence
- Safe Entry into Electrical Substations requires PPE and awareness of the Hazards
- The NESC, National Electrical Safety Code requires that all entrants notify the authority of their entry. This authority would be the System Operators – 616-836-0878- 616-355-1681 or 33 radio
- All personnel that enter a substation need to be authorized, qualified or escorted with someone who is
- A hardhat, safety glasses, work boots, and FR clothing are required at all times within the substation
- While inside a substation do not lift or raise shovels, rakes, tape measures, conduit, etc where they can come close to energized components of the substation a 13 foot clearance shall be maintained
- There is potential for arc, shock, and or blast from objects coming in or close contact with electrical components
- While inside the control house batteries pose a danger of shock, arc, and explosion. The chemical contact can cause life threatening conditions. Always keep a distance around the batteries unless you are qualified and the proper PPE is worn
- Substations shall be locked at all times unless occupied by authorized or qualified personnel While inside the substation personnel shall keep doors closed and monitored, or locked
- No switches, handles, breakers shall be operated except by qualified personnel
- Communication devices such as cell phones and radios shall not be operated with 4 feet of electronic equipment
- Substations shall be kept secure to keep out wild life, children, and unauthorized public out
- Cords, cables, pipe, etc can rise in potential and should be grounded to reduce the risk of injury
- In the event something should happen System Operations shall be called immediately 616-836-0878 or 616-355-1681
- Mayday - Mayday – Mayday- Man down (Location and Vital information of person down)  
**41 or 33** will respond to call.

Signature and date of participant(s):

1.	_____	Date	_____	.
2.	_____	Date	_____	.
3.	_____	Date	_____	.
4.	_____	Date	_____	.
5.	_____	Date	_____	.
6.	_____	Date	_____	.